

Test Report

Report Number: 150109034GZU-003

Applicant Name :

Report Date : 2015-04-29

Applicant Address :

Attn :

Sample Description:

This report pertains only to the sample models listed in the Product Description section of this report. The evaluated production model was submitted via the client's own courier on January 18, 2015. These samples were evaluated between January 18, 2015 and April 29, 2015 and were received in good condition at the Intertek Guangzhou laboratory located at Block E, No.7-2 Guang Dong Software Science Park, Cai Pin Road, Science city, Guangzhou Economic Development Zone, Guangzhou, P. R. China.

Product name: Fiber Cement Flat Sheet

Trade mark: FC

Model No.: 6mm and 18mm.

Conclusion:

1. Content of asbestos

Test method: With reference to NOISH 9002

No asbestos was detected.


Should you have any query on this report, you may contact at lillian.lf.He@intertek.com

Approved by:



Jeff Deng
Assistant Manager

Prepared by:



Jones Zhong
Project Engineer

Terms and Conditions

This report is made solely on the basis of your instructions and/or information and materials supplied by you. It is not intended to be a recommendation for any particular course of action. Intertek does not accept a duty of care or any other responsibility to any person other than the Client in respect of this report and only accepts liability to the Client insofar as is expressly contained in the terms and conditions governing Intertek's provision of services to you. Intertek makes no warranties or representations either express or implied with respect to this report save as provided for in those terms and conditions. We have aimed to conduct the Review on a diligent and careful basis and we do not accept any liability to you for any loss arising out of or in connection with this report, in contract, tort, by statute or otherwise, except in the event of our gross negligence or wilful misconduct.

The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

TTRF-PERF-02-EN Approved Date: May 5, 2014

Intertek Testing Services Shenzhen Ltd. Guangzhou Branch

Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China
Tel: 86 20 8213 9688 Fax: 86 20 3205 7538 www.intertek.com

Test Report

Report Number: 150109034GZU-003


Test Items, Method and Results:

*When determining the test result, measurement uncertainty has been considered.
If related to subcontract, the remark* for the test items conducted by a subcontractor.*

- 1 Content of asbestos
Requirement: Shall be absent.
With reference to NOISH 9002, qualitative assessment conducted by microscopic examination method.
Microscopical magnification: 400x
Analyte: Actinolite, Amosite, Crocidolite, Tremolite, Anthophyllite, Chrysotile

Test Result:
No asbestos was detected.
Verdict: Pass

Sample Photo



Revision Summary

DD/MM/YYYY	Project Engineer/ Reviewer	Page #	Project No	Reason for revision
29/04/2015	Jones Zhong/ Jeff Deng	2	150109034GZU-003	First issue

The End of The Report